

# Earthquake test of ANK-solid



The company Almatec AG, Industriestrasse 6, 6170 Schüpfheim, hereby confirms that the ANK-solid enclosure passed the earthquake test as specified in the standard  
**ETSI EN 300-019-2-4 V2.2.2 (2003-04) T 4.1, 4.1E**

The test was performed on an enclosure of type RSDLUC1000 (ANK-solid). Please note that the test result applies only to the empty enclosure. The installed components and interfaces to the enclosure must each be tested separately.

Schüpfheim, 16 December 2009

ALMATEC AG  
Industriestr. 6  
6170 Schüpfheim  
Tel. 041 / 485 77 77  
Fax: 041 / 485 77 88

  
ppa. M. Stalder, Quality Manager